

# **BEAVER COUNTY CLERK**

**LISA BENNETT**

**P. O. BOX 338**

**BEAVER, OKLAHOMA 73932**

**PHONE 580 625-3151**

## **TO WHOM IT MAY CONCERN:**

Bids will be received until **April 6, 2018 at 5:00 P.M.** in the Beaver County Clerk's Office of the Beaver County Courthouse in Beaver, Oklahoma.

Said bids will be publicly opened and considered by the Board of Beaver County Commissioners in the Commissioner's Office on the **9<sup>th</sup> day of April, 2018 at 10:00 A.M.** with the right being reserved to reject any or all bids.

The following criteria should be met when submitting a bid:

1. The bid shall be made on the enclosed "Invitation to Bid" and the Affidavit of Non-Collusion must be signed and notarized.
2. All prices quoted shall be F.O.B. Beaver County.
3. Place your bid in a sealed envelope clearly marked, "**SEALED BID #6**". This insures that the bid will not be voided due to accidental opening.
4. On all bids requiring services or contract labor, proof of liability insurance with at least \$1,000,000.00 liability and Workmen's Compensation is required. If you cannot furnish these you must furnish us with a Certificate of Non-Coverage.
5. **All bids on public construction contracts exceeding \$50,000.00 shall accompany the bid with a certified check, cashier's check or bid bond equal to 5% of the bid, which shall be deposited with the awarding public agency as a guaranty. Or, an irrevocable letter of credit issued by a financial institution, insured by the FDIC on behalf of the awarding public agency, in an amount equal to 5% of the bid.**
6. **Contract will not be executed until all bonds (Payment, Performance and Warranty) and insurance are provided.**

**NOTE: ALL BID PROPOSALS WILL BE DEEMED INVALID AND THEREFORE REJECTED WHICH DO NOT CONTAIN THE "INVITATION TO BID" AND THE SIGNED AND NOTARIZED "NON-COLLUSION AFFIDAVIT".**

Thank you for your cooperation and participation in this bidding procedure. Should you have any questions, please feel free to contact the Beaver County Clerk's Office at (580) 625-3151.

Respectfully,

Lisa Bennett  
Beaver County Clerk

**Lisa Bennett, Beaver County Clerk**  
**COUNTY PURCHASING OFFICE**  
 P.O. Box 338  
 Beaver, Oklahoma  
 Phone: (580) 625-3151

**INVITATION TO BID**

<b>3/8/2018</b>
<b>1 OF 3</b>

PLEASE REVIEW TERMS AND CONDITIONS ON REVERSE SIDE RELATING TO SUBMISSION OF THIS BID.

Notarized Affidavit completions and signature required on reverse side.

BID NUMBER	BID CLOSING DATE AND HOUR	REQUIRED DELIVERY DATE
#6	April 6, 2018 @ 5:00 P.M.	

TERMS:	DATE OF DELIVERY:
--------	-------------------

Item	Quantity	Unit of Issue	Description	Unit Price	Total
			<p>The Board of County Commissioners will open sealed bids for interior and exterior recoating repairs on the Turpin RWD water tower, as per the attached specifications.</p> <p><b>Contract will be signed upon bid award.</b></p> <p><b>Bids will be opened on April 9, 2018 at 10:00 A.M.</b></p> <p><b>The Board reserves the right to reject any or all bids.</b></p>		

**TERMS AND CONDITIONS**

1. Sealed bids will be opened in the Commissioner's Conference Room, \_\_\_\_\_ Beaver \_\_\_\_\_  
County Courthouse, \_\_\_\_\_ Beaver \_\_\_\_\_, Oklahoma, at the time and date shown on the  
invitation to bid form.
2. Late bids will not be considered. Bids must be received in sealed envelopes (one to an envelope) with bid number  
and closing date written on the outside of the envelope.
3. Unit prices will be guaranteed correct by the bidder.
4. Firm prices will be F.O.B. destination.
5. Purchases by \_\_\_\_\_ Beaver \_\_\_\_\_ County, Oklahoma, are not subject to state or federal taxes.
6. This bid is submitted as a legal offer and any bid when accepted by the County constitutes a firm contract.
7. Oklahoma laws require each bidder submitting a bid to a county for goods or services to furnish a notarized  
sworn statement of non-collusion. A form is supplied below.
8. Bids will be firm until \_\_\_\_\_  
(Date)

AFFIDAVIT: I, the undersigned, of lawful age, being first duly sworn on oath say that he (she) is the agent authorized  
by the bidder to submit the above bid. Affiant further states that the bidder has not been a party to any collusion  
among bidders in restraint of freedom of competition by agreement to bid at a fixed price or to refrain from bidding;  
or with any state official or employee as to quantity; quality or price in the prospective contract or any other terms  
of said prospective contract; or in any discussion between bidders and any state official concerning exchange of  
money or other thing of value for special consideration in the letting of a contract; that the bidder/contractor has not  
paid, given or donated or agreed to pay, give or donate to any officer or employee of the State of Oklahoma (or  
other entity) any money or other thing of value, either directly or indirectly in the procuring of the award of a contract  
pursuant to this bid.

Subscribed and sworn before this \_\_\_\_\_ day  
of \_\_\_\_\_ 20 \_\_\_\_\_.

My commission expires \_\_\_\_\_

\_\_\_\_\_  
NOTARY PUBLIC (CLERK OR JUDGE)

(SEAL)

Firm: \_\_\_\_\_

Signed by: \_\_\_\_\_ Title: \_\_\_\_\_

Print Name: \_\_\_\_\_

Address: \_\_\_\_\_ Phone: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_

Zip: \_\_\_\_\_

NOTE: Other terms and conditions can be added at the discretion of the county officer.

# **SPECIFICATIONS FOR THE RECOATING OF THE TURPIN RWD WATER TOWER**

Contractor shall furnish all labor, material and equipment to complete the following:

One (1) 63,000 gallon welded, standpipe, 11' diameter x 90' high

## **INTERIOR RECOATING**

Sandblast, SSPC-SP10, all rusted and abraded interior areas and brush blast, SSPC-SP7, all remaining interior areas. All areas sandblasted to a #10. Weld seams will receive one (1) spot coat of epoxy primer. One (1) full coat of epoxy will be applied to entire tank to achieve 8 to 10 mils of total dry film thickness.

## **EXTERIOR RECOATING**

Pressure wash the exterior of the tank and support structure using an anti-fungal biodegradable solution and hand tool clean as necessary. Apply one (1) spot primer coat of metal primer and one (1) complete finish coat of dry fall acrylic.